



# The Standards Institution of Israel

This is to certify that:

Astronomical Timer and Astronomical Timer Terminal

Models:

Astronomical Timer: B120

Astronomical Timer Terminal: B220

Electrical ratings:

B120: 230Vac, 50Hz, 0.2A

B220: 4.5Vdc (from internal batteries)

Manufactured by: Bar-Ore Computers Ltd.

Address: Bdg. 3, Industrial Center,  
Maale Shomron 44852, Israel

has been tested by SII and found to comply with  
the standard requirements of:

EN 61010-1 "Safety requirements for electrical  
equipment for measurement,  
control, and laboratory use  
Part 1: General requirements", 2001

Test results are detailed in SII Test Report No.: 8812348410.

Certificate No.: 8812348410

Date of issue: 12/11/2008

Eng. Michael Terman

Acting Head of Electrical Safety Branch  
Electronics and Telematics Laboratory

